

Options: for DBA-EA


page 2 of 2



DBA-EA23/A
DBA-EA30/A

Option: **H** Display-Hold

connection




Input	active-high, 24V
L-signal	display shows current measurement value
H-signal	display stores last measurement value

Option: **R** 2 Relais Contacts

programming

connection

10 Watt max.
max. 200V (0,05A)
max. 0,5A (20V)




code nr.	display	scale	description
7	S1		upper switching threshold
8	S1		lower switching threshold
9	--1 --0 --1 --2 --3 0-- 1--		0 = inactive operating current quiescent current operating current quiescent current display normal if S1 active display is flashing if S1 active

code nr.	display	scale	description
A	S2		upper switching threshold
b	S2		lower switching threshold
C	--1 --0 --1 --2 --3 0-- 1--		0 = inactive operating current quiescent current operating current quiescent current display normal if S1 active display is flashing if S1 active

Option: **S** Serial output RS232

programming

connection



code nr.	display	description
7	--0 --- --- --- ---	0 = 150 Baud 4 = 2400 Baud 1 = 300 Baud 5 = 4800 Baud 2 = 600 Baud 6 = 9600 Baud 3 = 1200 Baud 7 = 19200 Baud
	--0 --- --- --- ---	0 = without parity 8 data bits 1 = parity even 7 data bits 2 = parity odd 7 data bits 3 = parity even 8 data bits 4 = parity odd 8 data bits
8	--0 --X --X	address of display unit no address address 10 ⁰ address 10 ¹

code nr.	display	description
9	--0 --0 --- --- --- ---	direction of writing 0 = left, 1 = right 0 = serial output off 1 = digit sign / value 2 = STX/ sign /value /ETX 3 = STX/ adr. / sign /value /ETX 4 = SOH/ adr. /STX/ sign /value /ETX
	--0 1-- 2--	transfer instruction off transfer after received address transfer after STX/adr./ETX received

Option: **-M** min.-max.-memory function

Controls are accessible through the front glass. Reference measurement with T1.
Recall min. and max. value with T2 and T3.

GS Gebhardt & Schäfer Industrie-Elektronik GmbH

Moltkestraße 44a, D-42799 Leichlingen
Postfach 15 52, D-42786 Leichlingen
Tel. +49 (0) 21 75 / 89 91 30
Fax +49 (0) 21 75 / 89 91 39
Internet: <http://www.GS-GmbH.de>
E-Mail: info@GS-GmbH.de

Deutsche Bank 24
Konto-Nr. 851 085 100
BLZ 375 700 24
Kreissparkasse Köln
Konto-Nr. 031 200 61 45
BLZ 370 502 99

Foreign Payments:
Deutsche Bank 24
Account-No. 851 085 1
Bank Code 375 700 24
IBAN DE 81375700240008510851
S.W.I.F.T. DEUTDEK 375

Geschäftsführer:
Karlheinz Schäfer
Guido Gebhardt
USt.-Nr. DE 123713297
Amtsgericht Köln
HRB 48860